



CENTRAL POLLUTION CONTROL BOARD
Central Pollution Control Board, 'Parivesh Bhavan', East Arjun Nagar, Delhi -
110032



BIO-SCIENCE LABORATORY

Micro Biological Analysis Report

TC-7723

ULR No:

- | | | | |
|-----|--|---|--------------------------------|
| 1. | Report No. & Date of Issue | : | ,01/01/0001 |
| 2. | Samples Registration No. & Date | : | BIO/MB/2324/SR00002,01/08/2023 |
| 3. | Analysis Request Division/Organization | : | WQM-II |
| 4. | Sample Collected by | : | Mr. Rakesh Ahuja, Mr. Ravindra |
| 5. | Sampling Plan Preference | : | |
| 6. | Date of Sample Receipt | : | 01/08/2023 |
| 7. | Sample Analysis Period | : | 01/08/2023 03/08/2023 |
| 8. | Sample Details | : | STP Bijnor and Narora |
| 9. | Report Status | : | Partial |
| 10. | Report Sent to | : | DH of WQM-II |

SR. NO	Field Code	Sample Matrix	Date & Time of Sample Collection	Unit	Parameters	Result Val
1	B3	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Faecal Coliforms	2000000
2	B3	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Total Coliforms	33000000
3	B6	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Faecal Coliforms	1700000
4	B6	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Total Coliforms	16000000
5	NN3	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Faecal Coliforms	110000000000
6	NN3	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Total Coliforms	280000000000
7	NN6	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Faecal Coliforms	49000
8	NN6	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Total Coliforms	540000
9	N3	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Faecal Coliforms	280000000000
10	N3	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Total Coliforms	16000000000000
11	N6	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Faecal Coliforms	270000000
12	N6	Waste Water	31-07-2023 10:30 AM to 05:30 PM		Total Coliforms	3500000000

Remarks (if any) :

Statement :

1. The results relate only to the samples tested
2. The report shall not be reproduced except in full, without the written approval of the Competent authority of CPCB.
3. The sample will be retained for one week from the date of issue of this test report.
4. <1.8 MPN/100 ml indicates that the probability of presence of coliform in the sample is zero.

Analyst

Supervisor & Reviewer

Issued By(DH Bio-Science Lab)

Doc:	Issue No.:	Revision No :	Issue Date:01/01/0001	Revision Date: 01/01/0001
------	------------	---------------	-----------------------	---------------------------



CENTRAL POLLUTION CONTROL BOARD
Central Pollution Control Board, 'Pariveshh Bhavan', East Arjun Nagar, Delhi -
110032



BIO-SCIENCE LABORATORY
Micro Biological Analysis Report

TC-7723

Date: 16 Aug 2023

ULR No:

This is a computer-generated Report. No signature is required.