



CENTRAL POLLUTION CONTROL BOARD  
HEAD OFFICE - DELHI  
Parivesh Bhavan, East Arjun Nagar, Delhi - 110032



BIO-SCIENCE LABORATORY  
Micro Biological Analysis Report

TC-7723

ULR No:

1. Report No. & Date of Issue : ,01/01/0001
2. Report Sent To : DH of WQM-II  
(Name, Mobile no. & Address of Indentor)
3. Samples Registration No. & Date : BIO/MB/2324/SR00047, 13/10/2023
4. Analysis Request Division/Organization : WQM-II
5. Sample Collected by : Reena Satavan,
6. Sampling Plan Preference :
7. Date & Time of Sample Receipt : 13/10/2023 11:12 AM
8. Sample Analysis Period : 13/10/2023 15/10/2023
9. Sample Details :
10. Report Status : Partial

SR. NO	Field Code	Sample Matrix	Date & Time of Sample Collection	Parameters	Result value
1	BULT	Fresh Water	12-10-2023 11:14	Faecal Coliforms	
2	BDLT	Fresh Water	12-10-2023 12:30	Faecal Coliforms	
3	BUST	Fresh Water	12-10-2023 13:30	Faecal Coliforms	
4	SBBT	Fresh Water	12-10-2023 13:45	Faecal Coliforms	
5	BDST	Fresh Water	12-10-2023 14:15	Faecal Coliforms	230
6	PBC	Fresh Water	12-10-2023 14:00	Faecal Coliforms	1300
7	HD6	Waste Water	12-10-2023 14:30	Faecal Coliforms	7000
8	HD6	Waste Water	12-10-2023 14:30	Total Coliforms	3300
9	STT	Waste Water	11-10-2023 11:20	Faecal Coliforms	140000
10	STT	Waste Water	11-10-2023 11:20	Total Coliforms	540000

BDL : Below Deduction Limit

Remarks (if any) :

Statement :

1. The results relate only to the samples tested
2. The report shall not be reproduced except in full, without the written approval of the Competent authority of CPCB.
3. The sample will be retained for one week from the date of issue of this test report.
4. <1.8 MPN/100 ml indicates that the probability of presence of coliform in the sample is zero.

Analyst

Supervisor & Reviewer

Issued By(DH Bio-Science Lab)

Doc: CB/CL/QR/7.8/BL-1	Issue No.: 04	Revision No : 05	Issue Date:27/03/2014	Revision Date: 20/05/2022
------------------------	---------------	------------------	-----------------------	---------------------------

Date: 18 Oct 2023

This is a computer-generated Report. No signature is required.



CENTRAL POLLUTION CONTROL BOARD  
HEAD OFFICE - DELHI  
Parivesh Bhavan, East Arjun Nagar, Delhi - 110032



TC-7723

BIO-SCIENCE LABORATORY  
Micro Biological Analysis Report

ULR No:

Parameter Name	Test Method	Unit	Limit of Detection	Uncertainty of Measurement
Faecal Coliforms	APHA, 9221-E, 9-77 to 9-78, 23rd Ed.,: 2017	MNP/100 ml	1.8	
Total Coliforms	APHA, 9221-A,B,C, 9-68 to 9-75, 23rd Ed., : 2017, APHA, 9221-A,B,C, 9-68 to 9-75, 23rd Ed.,: 2017	MPN/100 mL	1.8	