



CENTRAL POLLUTION CONTROL BOARD  
HEAD OFFICE - DELHI  
Parivesh Bhavan, East Arjun Nagar, Delhi - 110032



Trace Organics Laboratory  
Organochlorine Pesticides Analysis Report

ULR No: TC772323400000005F

1. Report No. & Date of Issue : TOL/2324/OCPS/00005,05/10/2023
2. Report sent to : DH of WQM-II  
(Name, Mobile no. & Address of Indentor)
3. Samples Registration No. & Date : TOL/OCPS/2324/SR00007,04/09/2023
4. Analysis Request Division/Organization : WQM-II
5. Sample Collected by : Dr. Chandravir Narayan, Dr. Swati Singh
6. Sampling Plan Preference :
7. Sample Sealing Status : Not-Sealed
8. Date & Time of Sample Receipt : 04/09/2023 12:43 PM
9. Sample Analysis Period : 06/09/2023 22/09/2023
10. Sample Details : Waste water
11. Report Status : Final

Sr. No	Field Code	Parameter Name	Date of Sample Collection	Sample Matrix	Unit	Result value
1	V6	Aldrin	01/09/2023	Waste Water		BDL
2	V6	Dieldrin	01/09/2023	Waste Water		BDL
3	V6	Heptachlor	01/09/2023	Waste Water	O	BDL
4	V6	o,p DDT	01/09/2023	Waste Water	O	BDL
5	V6	p,p DDD	01/09/2023	Waste Water	O	BDL
6	V6	p,p DDE	01/09/2023	Waste Water	O	BDL
7	V6	p,p DDT	01/09/2023	Waste Water	O	BDL
8	V6	-	01/09/2023	Waste Water		BDL
9	V6	Endosulfan	01/09/2023	Waste Water	O	BDL
10	V6	HCH	01/09/2023	Waste Water		BDL
11	V6	HCH	01/09/2023	Waste Water	O	BDL
12	V6	HCH	01/09/2023	Waste Water	O	BDL
13	M6	Aldrin	01/09/2023	Waste Water		BDL
14	M6	Dieldrin	01/09/2023	Waste Water		BDL
15	M6	Heptachlor	01/09/2023	Waste Water	O	BDL
16	M6	o,p DDT	01/09/2023	Waste Water	O	BDL
17	M6	p,p DDD	01/09/2023	Waste Water	O	BDL
18	M6	p,p DDE	01/09/2023	Waste Water	O	BDL
19	M6	p,p DDT	01/09/2023	Waste Water	O	BDL
20	M6	-	01/09/2023	Waste Water		BDL
21	M6	Endosulfan	01/09/2023	Waste Water	O	BDL
22	M6	HCH	01/09/2023	Waste Water		BDL
23	M6	HCH	01/09/2023	Waste Water	O	BDL



CENTRAL POLLUTION CONTROL BOARD  
HEAD OFFICE - DELHI  
Parivesh Bhavan, East Arjun Nagar, Delhi - 110032



Trace Organics Laboratory  
Organochlorine Pesticides Analysis Report

ULR No: TC77232340000005F

24	M6	HCH	01/09/2023	Waste Water	O	BDL
25	T6	Aldrin	01/09/2023	Waste Water		BDL
26	T6	Dieldrin	01/09/2023	Waste Water		BDL
27	T6	Heptachlor	01/09/2023	Waste Water	O	BDL
28	T6	o,p DDT	01/09/2023	Waste Water	O	BDL
29	T6	p,p DDD	01/09/2023	Waste Water	O	BDL
30	T6	p,p DDE	01/09/2023	Waste Water	O	BDL
31	T6	p,p DDT	01/09/2023	Waste Water	O	BDL
32	T6	-	01/09/2023	Waste Water		BDL
33	T6	Endosulfan	01/09/2023	Waste Water	O	BDL
34	T6	HCH	01/09/2023	Waste Water		BDL
35	T6	HCH	01/09/2023	Waste Water	O	BDL
36	T6	HCH	01/09/2023	Waste Water	O	BDL
37	MT6	Aldrin	01/09/2023	Waste Water		BDL
38	MT6	Dieldrin	01/09/2023	Waste Water		BDL
39	MT6	Heptachlor	01/09/2023	Waste Water	O	BDL
40	MT6	o,p DDT	01/09/2023	Waste Water	O	BDL
41	MT6	p,p DDD	01/09/2023	Waste Water	O	BDL
42	MT6	p,p DDE	01/09/2023	Waste Water	O	BDL
43	MT6	p,p DDT	01/09/2023	Waste Water	O	BDL
44	MT6	-	01/09/2023	Waste Water		BDL
45	MT6	Endosulfan	01/09/2023	Waste Water	O	BDL
46	MT6	HCH	01/09/2023	Waste Water		BDL
47	MT6	HCH	01/09/2023	Waste Water	O	BDL
48	MT6	HCH	01/09/2023	Waste Water	O	BDL
49	CK6	Aldrin	01/09/2023	Waste Water		BDL
50	CK6	Dieldrin	01/09/2023	Waste Water		BDL
51	CK6	Heptachlor	01/09/2023	Waste Water	O	BDL
52	CK6	o,p DDT	01/09/2023	Waste Water	O	BDL
53	CK6	p,p DDD	01/09/2023	Waste Water	O	BDL
54	CK6	p,p DDE	01/09/2023	Waste Water	O	BDL
55	CK6	p,p DDT	01/09/2023	Waste Water	O	BDL
56	CK6	-	01/09/2023	Waste Water		BDL
57	CK6	Endosulfan	01/09/2023	Waste Water	O	BDL
58	CK6	HCH	01/09/2023	Waste Water		BDL
59	CK6	HCH	01/09/2023	Waste Water	O	BDL
60	CK6	HCH	01/09/2023	Waste Water	O	BDL



CENTRAL POLLUTION CONTROL BOARD  
HEAD OFFICE - DELHI  
Parivesh Bhavan, East Arjun Nagar, Delhi - 110032



TC-7723

Trace Organics Laboratory  
Organochlorine Pesticides Analysis Report

ULR No: TC772323400000005F

61	JC6	Aldrin	01/09/2023	Waste Water		BDL
62	JC6	Dieldrin	01/09/2023	Waste Water		BDL
63	JC6	Heptachlor	01/09/2023	Waste Water	O	BDL
64	JC6	o,p DDT	01/09/2023	Waste Water	O	BDL
65	JC6	p,p DDD	01/09/2023	Waste Water	O	BDL
66	JC6	p,p DDE	01/09/2023	Waste Water	O	BDL
67	JC6	p,p DDT	01/09/2023	Waste Water	O	BDL
68	JC6	-	01/09/2023	Waste Water		BDL
69	JC6	Endosulfan	01/09/2023	Waste Water	O	BDL
70	JC6	HCH	01/09/2023	Waste Water		BDL
71	JC6	HCH	01/09/2023	Waste Water	O	BDL
72	JC6	HCH	01/09/2023	Waste Water	O	BDL
73	NB6	Aldrin	01/09/2023	Waste Water		BDL
74	NB6	Dieldrin	01/09/2023	Waste Water		BDL
75	NB6	Heptachlor	01/09/2023	Waste Water	O	BDL
76	NB6	o,p DDT	01/09/2023	Waste Water	O	BDL
77	NB6	p,p DDD	01/09/2023	Waste Water	O	BDL
78	NB6	p,p DDE	01/09/2023	Waste Water	O	BDL
79	NB6	p,p DDT	01/09/2023	Waste Water	O	BDL
80	NB6	-	01/09/2023	Waste Water		BDL
81	NB6	Endosulfan	01/09/2023	Waste Water	O	BDL
82	NB6	HCH	01/09/2023	Waste Water		BDL
83	NB6	HCH	01/09/2023	Waste Water	O	BDL
84	NB6	HCH	01/09/2023	Waste Water	O	BDL
85	NA6	Aldrin	01/09/2023	Waste Water		BDL
86	NA6	Dieldrin	01/09/2023	Waste Water		BDL
87	NA6	Heptachlor	01/09/2023	Waste Water	O	BDL
88	NA6	o,p DDT	01/09/2023	Waste Water	O	BDL
89	NA6	p,p DDD	01/09/2023	Waste Water	O	BDL
90	NA6	p,p DDE	01/09/2023	Waste Water	O	BDL
91	NA6	p,p DDT	01/09/2023	Waste Water	O	BDL
92	NA6	-	01/09/2023	Waste Water		BDL
93	NA6	Endosulfan	01/09/2023	Waste Water	O	BDL
94	NA6	HCH	01/09/2023	Waste Water		BDL
95	NA6	HCH	01/09/2023	Waste Water	O	BDL
96	NA6	HCH	01/09/2023	Waste Water	O	BDL

BDL : Below Deduction Limit



CENTRAL POLLUTION CONTROL BOARD  
HEAD OFFICE - DELHI  
Parivesh Bhavan, East Arjun Nagar, Delhi - 110032



TC-7723

Trace Organics Laboratory  
Organochlorine Pesticides Analysis Report

ULR No: TC772323400000005F

Remarks (if any) :

Statement :

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.

Analyst

Supervisor & Reviewer

Issued By(DH TOL-Lab)

Charu Sharma

Bhupander Kumar

Sanjay Kumar

Doc: CB/CL/QR/7.8/TOL-1	Issue No.:01	Revision No : 08	Issue Date: 18/12/2017	Revision Date: 05/05/2022
-------------------------	--------------	------------------	------------------------	---------------------------

Date: 12 Dec 2023

This is a computer-generated Report. No signature is required.

Parameter Name	Test Method	Unit	Limit of Detection	Uncertainty of Measurement
Aldrin	USEPA Method No. 8081B, 2007		0.100	. 0 . . 0
Dieldrin	USEPA Method No. 8081B, 2007		0.100	. 0 . . 0
Heptachlor	USEPA Method 8081B : 2007	O	0.100	. 0 . . 0
o,p DDT	USEPA Method 8081B : 2007	O	0.100	. 0 . . 0
p,p DDD	USEPA Method 8081B : 2007	O	0.100	. 0 . . 0
p,p DDE	USEPA Method 8081B : 2007	O	0.100	. 0 . . 0
p,p DDT	USEPA Method 8081B : 2007	O	0.101	. 0 . . 0
-	USEPA Method No. 8081B, 2007		0.102	. 0 . . 0
Endosulfan	USEPA Method 8081B : 2007	O	0.101	. 0 . . 0
HCH	USEPA Method No. 8081B, 2007		0.100	. 0 . . 0
HCH	USEPA Method 8081B : 2007	O	0.100	. 0 . . 0
HCH	USEPA Method 8081B : 2007	O	0.100	. 0 . . 0