



CENTRAL POLLUTION CONTROL BOARD
REGIONAL DIRECTORATE KOLKATA
Regional Directorate, 502 Southend Conclave, 6th Floor, 1582 Rajdanga Main Road, Kolkata- 700107

Water Laboratory (ANALYSIS REPORT)
Waste Water Samples for Physico-Chemical Analysis Report

Samples Registration No. & Date : RDKL/WW/2324/SR00077, 13/12/2023 Report No. & Date of Issue : RDKL/2324/WW/00173,21/12/2023
Analysis Request Division/Organization : RD Kolkata Report sent to (Name,Mobile no. & Address of Indentor) : DH of RD Kolkata
Sample Details : M/s Globus Spirits Limited, Panagarh, West Bengal Sample Matrix : Waste Water
Sample Collected by : Md. A. Rafique,Ajay Kumar Dubey, SSA Date & Time of Sample Receipt : 13/12/2023 11:23 AM
Sampling Plan Preference : Sample Analysis Period : 13/12/2023 to 16/12/2023
Report Status : Final

Sr.No	Date of Sample Collection	Field Code	Colour
1	12/12/2023	S-1	50
2	12/12/2023	S-2	50
3	12/12/2023	S-3	20
4	12/12/2023	S-4	20
5	12/12/2023	S-5	30

BDL : Below Deduction Limit

Remarks (if any) :

Analyst

Supervisor & Reviewer

Issued By (DH Water-Lab)

Md Abdur Rafique

Abhijit Pathak

Doc: CB/RDK/TR/QR/7.8/2

Issue No.:01

Revision No :01

Issue Date:20/01/2020

Revision Date: 08/12/2022

Page No. : 1/2



CENTRAL POLLUTION CONTROL BOARD
REGIONAL DIRECTORATE KOLKATA
Regional Directorate, 502 Southend Conclave, 6th Floor, 1582 Rajdanga Main Road, Kolkata- 700107

Water Laboratory (ANALYSIS REPORT)
Waste Water Samples for Physico-Chemical Analysis Report

Statement :

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full without written approval of the laboratory
3. BDL & Test methods are mentioned on back side of this report.
4. Samples will be retained only for one week after receipt of Report.

Parameter Name	Test Method	Unit	Limit of Detection	Uncertainty of Measurement
Biochemical Oxygen Demand (20 deg. C for 5 days & 27 deg.C for 3 days)	APHA 24th Ed., 5210 B Part 5000.533 to 537	mg/l	1 mg/l	
Chemical Oxygen Demand	APHA 23th Ed. 5220 B. Part 5000.544 to 545	mg/l	2 mg/l	
Colour	APHA 24th Ed. 2120 B Part 2000.82 to 83	CU		
pH	APHA 24th Ed. 4500-H+B Part 4000.473-478		2	
Total Suspended Solids	APHA 24th Ed. 2540-D Part 2000.146 to 147	mg/l	5 mg/l	

Analyst

Supervisor & Reviewer

Issued By (DH Water-Lab)

Md Abdur Rafique

Abhijit Pathak

Doc: CB/RDK/TR/QR/7.8/2

Issue No.:01

Revision No :01

Issue Date:20/01/2020

Revision Date: 08/12/2022

Page No. : 2/2