



CENTRAL POLLUTION CONTROL BOARD
REGIONAL DIRECTORATE KOLKATA
Regional Directorate, 502 Southend Conclave, 6th Floor, 1582 Rajdanga Main Road, Kolkata- 700107

Water Laboratory (ANALYSIS REPORT)
Fresh Water Samples for Physico-Chemical Analysis Report

Samples Registration No. & Date : RDKL/FW/2324/SR00016, 12/10/2023 Report No. & Date of Issue : RDKL/2324/FW/00023,15/11/2023
Analysis Request Division/Organization : RD Kolkata Report sent to (Name, Mobile no. & Address of Indentor) : DH of RD Kolkata
Sample Details : Ground Water, Keventer Agro Ltd, Barasat, West Bengal Sample Matrix : Fresh Water
Sample Collected by : Tofic Aslam, A. Kumar, A.K. Dubey, A.N. Thakur, T.K. Mukhopadhyay, O.P. Shaw Date & Time of Sample Receipt : 13/10/2023 16:58 PM
Sampling Plan Preference : RDKL/FW/2324/SP00016 Sample Analysis Period : 08/11/2023 to 10/11/2023
Report Status : Final

Sr.No	Date of Sample Collection	Field Code
-------	---------------------------	------------

BDL : Below Deduction Limit

Remarks (if any) :

Bch. 5 H Y W b W b F U j c b g U f Y Y d f Y g g Y X ' J o ' a [# Y I W d h d < U b X ' 7 c b X i W j j] m f l e a \ c # A d t f l e a \ c # A d t

Statement :

- 1.*****The results relate only to the samples tested.
- 2.*****The report shall not be reproduced except in full without written approval of the laboratory
- 3.*****BDL & Test methods are mentioned on back side of this report.
- 4.*****Samples will be retained only for one week after receipt of Report.

Parameter Name	Test Method	Unit	Limit of Detection	Uncertainty of Measurement
Arsenic	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	

Analyst

Supervisor & Reviewer

Issued By (DH Water-Lab)

Md Abdur Rafique

Abhijit Pathak

Doc: CB/RDK/TR/QR/7.8/1	Issue No.:01	Revision No :01	Issue Date:20/01/2020	Revision Date: 08/12/2022	Page No. : 1/2
-------------------------	--------------	-----------------	-----------------------	---------------------------	----------------



CENTRAL POLLUTION CONTROL BOARD
REGIONAL DIRECTORATE KOLKATA
Regional Directorate, 502 Southend Conclave, 6th Floor, 1582 Rajdanga Main Road, Kolkata- 700107

Water Laboratory (ANALYSIS REPORT)
Fresh Water Samples for Physico-Chemical Analysis Report

Cadmium	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	
Chemical Oxygen Demand	APHA 24th Ed. 5220 B. Part 5000.544 to 545	mg/l	2 mg/l	
Chloride	APHA 24th ed. 4500-Cl B Part 4000.340 to 341	mg/l	5 mg/l	
Chromium	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	
Conductivity	APHA 24th Ed. 2510- B Part 2000.134 to 135		3 uS/cm	
Copper	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	
Fluoride	APHA 24th. Ed. 4500-F D, Part 4000.400 to 401	mg/l	0.04 mg/l	
Iron	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	
Lead	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	
Manganese	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	
Nickel	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	
NO ₃ - N	APHA 24th Ed. 4500-NO ₃ E, Part 4000.438-440	mg/l	0.01 mg/l	
pH	APHA 24th Ed. 4500-H+B Part 4000.473-478		2	
Phosphate - P	APHA 24th Ed. 4500-P D Part 4000.485-486	mg/l	0.01 mg/l	
Sulphate	APHA 24th Ed. 4500-SO ₄ E Part 4000.505-506	mg/l	4 mg/l	
Total Alkalinity	APHA 24th Ed. 2320-B Part 2000.112 to 114	mg/l as CaCO ₃	8 mg/l	# #\
Total Dissolved Solids	APHA 24th Ed. 2540 C Part 2000.145	mg/l	5 mg/l	
Total Hardness as CaCO ₃	APHA 24th Ed. 2340-C Part 2000.124 to 126	mg/l as CaCO ₃	10 mg/l	# #\
Total Suspended Solids	APHA 24th Ed. 2540-D Part 2000.146 to 147	mg/l	5 mg/l	
Zinc	APHA 24th Ed. 3125 B Part 3000.233 to 242		10 ppb	

Analyst

Supervisor & Reviewer

Issued By (DH Water-Lab)

Md Abdur Rafique

Abhijit Pathak

Doc: CB/RDK/TR/QR/7.8/1

Issue No.:01

Revision No :01

Issue Date:20/01/2020

Revision Date: 08/12/2022

Page No. : 2/2