



CENTRAL POLLUTION CONTROL BOARD
REGIONAL DIRECTORATE KOLKATA
502 Southend Conclave, 6th Floor, 1582 Rajdanga Main Road, Kolkata- 700107

Water Laboratory (ANALYSIS REPORT)
Waste Water Samples for Physico-Chemical Analysis Report

Samples Registration No. & Date : RDKL/WW/2324/SR00055, 24/11/2023 Report No. & Date of Issue : RDKL/2324/WW/00184,26/12/2023
Analysis Request Division/Organization : RD Kolkata Report sent to (Name,Mobile no. & Address of Indentor) : DH of RD Kolkata
Sample Details : STP Sample Matrix : Waste Water
Sample Collected by : Kumar Ayush,Kumar Ayush,Saurabh Garg Date & Time of Sample Receipt : 29/11/2023 17:49 PM
Sampling Plan Preference : RDKL/WW/2324/SP00054 Sample Analysis Period : 07/12/2023 to 08/12/2023
Report Status : Final

Sr.No	Date of Sample Collection	Field Code	Total Nitrogen	Total Phosphorus
1	23/11/2023	P-1	22	4
2	23/11/2023	P-4	14	2.6

BDL : Below Deduction Limit

Remarks (if any) :

Statement :

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full without written approval of the laboratory
3. BDL & Test methods are mentioned on back side of this report.
4. Samples will be retained only for one week after receipt of Report.

Parameter Name	Test Method	Unit	Limit of Detection	Uncertainty of Measurement
----------------	-------------	------	--------------------	----------------------------

Analyst

Supervisor & Reviewer

Issued By (DH Water-Lab)

Md Abdur Rafique

Abhijit Pathak

Doc: CB/RDK/TR/QR/7.8/2	Issue No.:01	Revision No :01	Issue Date:20/01/2020	Revision Date: 08/12/2022	Page No. : 1/2
-------------------------	--------------	-----------------	-----------------------	---------------------------	----------------



CENTRAL POLLUTION CONTROL BOARD
REGIONAL DIRECTORATE KOLKATA
502 Southend Conclave, 6th Floor, 1582 Rajdanga Main Road, Kolkata- 700107

Water Laboratory (ANALYSIS REPORT)
Waste Water Samples for Physico-Chemical Analysis Report

Total Nitrogen				
Total Phosphorus	APHA 24th Edition 4500-P J	mg/l	0.1	

Analyst

Supervisor & Reviewer

Issued By (DH Water-Lab)

Md Abdur Rafique

Abhijit Pathak

Doc: CB/RDK/TR/QR/7.8/2

Issue No.:01

Revision No :01

Issue Date:20/01/2020

Revision Date: 08/12/2022

Page No. : 2/2